

Water filter Slimflow, Smartflow, Ecoflow, Flexflow, Miniflow, Notric

Holder/Issued to

WET BV

Doeneaertstraat 6, 8500 Kortrijk, Belgium

Product description

Aqua Danmark SlimSOFT, Aqua Danmark SmallSOFT, Aqua Danmark UltraSOFT, Basic SOFT, Ecoflow, Flexflow, Miniflow, Notric, Slimflow, Slim SOFT, Smartflow and Touch SOFT are water filter with associated equipment for water treatment, manufactured from materials suitable for contact with drinking water. The equipment is supplied with flexible connection hoses with G3/4" connections. Alloys in contact with water consist of SUS304 and CW617N.

Intended use

The water filters are used in cold tap water installations with a maximum working pressure of 1 MPa.

Trade name

Aqua Danmark SlimSOFT 100 & 200
Aqua Danmark SmallSOFT 100 & 200
Aqua Danmark UltraSOFT 515 & 1530
Basic SOFT 6
Ecoflow 100 & 200
Flexflow 800 & 1250
Miniflow
Notric
Slimflow 100 & 200
Slim SOFT 9 & 18
Smartflow 125 & 250
Touch SOFT 9 & 18

Approval

The products complies with the requirements of Chapter 8, Section 4, item 3 of the Planning and Building Act (2010:900), in the respects and under the conditions specified in this type approval.

The products meets the requirements of Chapter 4, Sections 12 of the Planning and Building Ordinance (2024:134) and has been assessed to not release harmful concentrations of hazardous substances into drinking water, not promote microbial growth, and not negatively affect the color, odor, or taste of the water.

The approval covers the parts of the Swedish National Board of Housing, Building and Planning's (Boverket's) regulations and general recommendations specified below:

Approval, continuing

Boverket's regulations with regard to hygiene, health and the environment, water management and waste management (BFS 2024:8):

Water- and sewage installations

BFS 2024:8, Ch. 8, Sec. 3, 4 and 6

Boverket's Building Regulations (BBR) (BFS 2011:6 as amended up to and including BFS 2024:5) ¹:

Installation of Tapwater

BBR 6:62

¹ May be applied to the extent stated in the transitional provisions of Boverket's regulations BFS 2024:14.

The type approval does not cover the function of the products. The suitability and effectiveness of any water filtration media and resin has not been assessed and is not part of this type approval.

Associated documents

n/a

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control plan: RISE CR 074 dated 2026-04-20, Inspection body: RISE

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing place

Production control includes the following place:

Factory code: WET

Marking

The products are to be marked at the factory. The marking consists of a sign/label/text on every product supplied and includes:

Holder	WET BV
Factory code	WET
Product type designation	<i>see trade name</i>
Consecutive manufacture no./date of production	<i>No./date</i>
Type approval number	C900037
Boverket's registered trade mark	
RISE Accreditation number	1002
Inspection body	RISE

Basis for approval

Certificates P1-054-01, 392-2024-00009801 rev1, 392-2024-00009902, 392-2024-00009901, 392-2021-00158102, 392-2021-00158101, 392-2020-00500802 and 392-2020-00500803 from Eurofins.

Certificate Z-340686-21-Hy220 from Hy.

Certificates HW-0804DO0240 and DW-0304CU0398 from DVGW.

Report 121-25879.0001 from FORCE Technology.

Report O100152-193596 from RISE.

Type Approval C900037 | issue 7 | 2026-09-09

RISE Research Institutes of Sweden AB | Certification

Comments

The product have been assessed as meeting the requirements of RISE Certification Rules CR 068, dated 2025-06-02.

This type approval supersedes the previous type approval with the same number dated 2026-06-04.

Validity

Valid up to and including 2031-06-30.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011 or 2024/3110.

A blue ink signature of Stefan Coric, written in a cursive style.

Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.